

Clark Fork Hourly Operations

Marc Baldo and James VanShaar (RTi) Heidi Heath (Avista Corp.)



Introduction





Introduction



Introduction



Project Goals

Planning tool to grade alternative operations

Avista plans big upgrade at Noxon dam

Four generators will get new turbine runners in \$35 million project

Journal of Business, May 29, 2008 by Ripley, Richard



Project Goals

Planning tool to grade alternative operations

- Provide realistic hourly operation
- Model turbine capacity changes
- Construction times versus cost
- Model pool elevation changes
- Retain sufficient simplicity avoiding the need for ongoing consultant expertise
- Look forward to optimization



Review and Strategic Design



Review and Strategic Design



- Review and Strategic Design
- Collaborative Development





AWISTA

- Review and Strategic Design
- Collaborative Development
- Model Enhancement and Support



🗖 RBS Ruleset Editor - "Clark Fork Rules 38. rls"								
File Edit Ruleset View								
Name: RiverWare Training\models\Ph3_rbs\Hourly\Clark Fork Rules38.rls RPL Set Not Loaded								
Name	Priority	0n	Туре					
🐨 🕼 Cabinet Rules		 Image: A start of the start of	Policy Group					
😑 🛅 Noxon Rules		~	Policy Group					
- 🖪 SaveDailyMaxValue	9	~	Rule					
- 🖪 NoxonOutflow	10	~	Rule					
🗌 🖪 Noxon Flood Release	11	~	Rule					
🗌 🖪 Noxon Limit Release for Erosion Contro	112	~	Rule					
🗌 🖪 Noxon Limit Release by Minimum Pool	13	~	Rule					
🗌 🖪 NoxonCalculateDelayedRelease	14	~	Rule					
NoxonLimitByTurbineCapacity	15	~	Rule					
🗌 🖪 NoxonReleaseRule	16	~	Rule					
SaveWeeklyFlow to TestSlot	17	~	Rule					
🗉 🛅 Historical Operation		×	Policy Group					
🗉 🛅 Initialization		~	Policy Group					
🐨 📓 Noxon Functions		~	Utility Group					
🖻 🕼 Cabinet Functions		~	Utility Group					
🖻 🛅 Generic Functions		~	Utility Group					

🔲 Open Object - Noxon Rap	pids			
File Edit View Slot Account				
- ^				
Object Name: Noxon Rap	ids			
Slots Methods Accounts				
December 31, 1990 👌				🔞 🗠 🛧 😃
Slot Name	Value	Units		
Best Hudro Capacity	NaN	MW	ាញ	
A Canal Flow	NaN	cfs	mm	
Convergence			فننبية فبنتنة	
Diversion	NaN	cfs	ារា	
Diversion Capacity	NaN	cfs		
Elevation Volume Table				
Energy	NaN	MWH	\square	
Flow FROM Pumped Storage	NaN	cfs		
Flow TO Pumped Storage	NaN	cfs	DD	
Hydro Capacity	NaN	MW	\square	
M Inflow	0.00	cfs		
Max Iterations				
Minimum Power Elevation				
Operating Head	NaN	ft	Ω	
Outflow	0.00	cfs	LI	
Plant Power Limit	NaN	MW	mm	
Plant Power Table				
Pool Elevation	2330.25	ft	I	
Power	NaN	MW	mm	
Power Coefficient	NaN	MW/cfs	$\overline{\mathbf{n}}$	
Power Curvature Tolerance	NaN	NONE		
Power Plant Cap Fraction	NaN	decimal	CO	
Regulated Spill	NaN	cfs	n	
Regulated Spill Drift Index	NaN	NONE		
🖩 Regulated Spill Index Table				
E Regulated Spill Table				
MReturn Flow	NaN	cfs		
🕅 Spill	NaN	cfs	DD	
Storage	113300.00	cfs-day		
🕅 Tailwater Base Value	2172.70	ft	LI	
Tailwater Elevation	NaN	ft		
🖽 Stage Flow Tailwater Table				
小 Total Inflows	NaN	cfs	\Box	
Tail Water Reference Elevatio	n			
Turbine Release	NaN	cfs	\square	
р ч				

Riverside Technology, inc.

AVISTA

Model Design

- Simulation Model
- Physical and operational constraints
- Power market
- Rule development
- Model results



Simulation Model

- Match physical and historical operations
 - Hourly operation 16 years of data
 - Cabinet pool elevation affects tailwater of Noxon Rapids
 - Power operation at both locations using plantEfficiencyCurve
 - Rulebased Simulation





Constraints

- Erosion control
 - Cannot decrease pool more than 2 ft / day or 5 ft / week
- Turbine capacity
 - Available capacity can change based on construction schedule

- Maximum/Minimum Pool Elevation
- Minimum stream flow below Cabinet



Power Market

- Hourly fluctuation in prices based on
 - Temperature
 - Day of week
 - Time of day
 - Season
 - External factors
- Operate to maximize benefit of hydropower
- Hourly prices could be used with optimization

AVISTA

Relative Prices per Hour Spring and Summer Days





Power Releases

- Correlation between releases and the hourly power price was low
 - Total water available
 - Physical constraints, such as starting or stopping individual units



Pool Limits

- Maximum / Minimum
 - Provided as a seasonal pattern (periodic)
 - Particularly helpful for maximum storage

- Provided limits for the release rule



Typical Release

- Release is a function of:
 - Weekly inflow
 - Date
 - Turbine capacity
 - Minimum pool
 - Maximum pool
 - Erosion limits
 - Minimum release

Name	Priority	On	Туре
📮 🐻 Cabinet Rules		 Image: A second s	Policy Group
🔤 🖪 CabinetOutflow	1	 Image: A set of the set of the	Rule
🔤 🖪 Cabinet Minimum Outflow	2	 Image: A set of the set of the	Rule
🔤 🖪 Cabinet Flood Release	3	 Image: A set of the set of the	Rule
🔤 🖪 Cabinet Limit Release by Minimum Pool	4	~	Rule
🔤 🖪 CabinetCalculateDelayedRelease	5	~	Rule
🔤 🖪 CabinetLimitByTurbineCapacity	6	 Image: A set of the set of the	Rule
🔤 🖪 CabinetReleaseRule	7	 Image: A set of the set of the	Rule
SaveWeeklyFlow to TestSlot	8	 Image: A second s	Rule
🕀 🚺 Noxon Rules		~	Policy Group
🖳 🖪 SaveDailyMaxValue	9	~	Rule
🖳 🖪 NoxonOutflow	10	~	Rule
🔤 🖪 Noxon Flood Release	11	~	Rule
🔤 🖪 Noxon Limit Release for Erosion Contro	12	~	Rule
🗝 🖪 Noxon Limit Release by Minimum Pool	13	~	Rule
🔤 🖪 NoxonCalculateDelayedRelease	14	~	Rule
🔤 🖪 NoxonLimitByTurbineCapacity	15	~	Rule
🔤 🖪 NoxonReleaseRule	16	~	Rule
🔤 🖪 SaveWeeklyFlow to TestSlot	17	~	Rule
💷 🛅 Historical Operation		×	Policy Group
💷 🛅 Initialization		 Image: A second s	Policy Group
🖶 🛅 Noxon Functions		 Image: A second s	Utility Group
🖶 🛅 Cabinet Functions		 Image: A second s	Utility Group
🖻 🐻 Generic Functions		~	Utility Group

AVISTA

Turbine Capacities

- Reduction in turbine capacity
 - Daily release variation is maintained
 - Excess release is stored
 - Pool elevation limits are enforced



Results



Conclusion

- The model and training were successfully delivered with project objectives fully met
- Avista currently runs the model
- Modeling results used for:
 - Construction / Maintenance timing
 - Estimating the benefits of planned improvements



